



Lincoln Street Well POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN MONTHLY

(As required if initial monthly sampling is over 10 ppt and under 20 ppt)

Lincoln Street Well POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
1/6/2021 (Exploratory Sample)	14.50
10/13/2021 (AA)	18.25
11/4/2021 (AA)	18.87
12/21/2021 (AA)	19.79
1/11/2022 (AA)	19.32
2/10/2022 (AA)	16.66
2/10/2022 (NECC)	10.54
3/8/2022 (AA)	20.07
3/8/2022 (NECC)	14.24
4/7/2022 (AA)	18.62
4/7/2022 (NECC)	10.22
5/10/2022 (AA)	17.90
5/10/2022 (NECC)	11.68
6/7/2022 (AA)	17.64
6/7/2022 (NECC)	11.46
7/7/2022 (AA)	18.26
7/7/2022 (NECC)	10.86
8/15/2022 (AA)	16.7
8/15/2022 (NECC)	11.4

Note: Split sampling began in February 2022 as lab results were known to vary.



Lincoln Street Well POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN MONTHLY

(As required if initial monthly sampling is over 10 ppt and under 20 ppt)

Lincoln Street Well POE/FW (Point of Entry/Finish Water)	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
8/5/2022 (AA)	16.7
8/5/2022 (NECC)	11.4
9/8/2022 (AA)	17.20
9/8/2022 (NECC)	12.40
10/5/2022 (AA)	15.30
10/5/2022 (NEC)	10.80
11/1/2022 (AA)	15.30
11/1/2022 (NEC)	10.40

Note: Split sampling began in February 2022 as lab results were known to vary.



Gravelly Pond POE/FW - Per- and Polyfluoroalkyl Substances (PFAS) Results

TESTS TAKEN QUARTERLY
(As required if initial sampling is under 10 ppt.)

Gravelly Pond POE/FW <i>(Point of Entry/Finish Water)</i>	
DATE	PFAS6 Total <i>ng/l (ppt)</i>
10/13/2021 (AA)	7.35
11/4/2021 (AA)	7.24
1/11/2022 (AA)	6.80
4/7/2022 (AA)	6.72
4/7/2022 (NECC)	2.94
7/7/2022 (AA)	7.89
7/7/2022 (NECC)	2.81
Next Sample: January 2023	

Note: Split sampling began in February 2022 as lab results were known to vary.

KEY:

AA - Alpha Analytical Lab

NECC - New England ChromaChem Lab

PPT - Parts per Trillion

POE/FW - Point of Entry/Finish Water